

# EFRC Training Workshop

## Design of Compressor Foundations

Foundation Repair and General Overhaul  
Harry Lankenau – NEAC Compressor Service



# Foundation Repair



# Foundation Repair / Frame Foot Movement Check

## Example No. 1

Gaps and movement had been visible here  
Complete frame was rocking



Sometimes oil or water bubbles indicate slight relative movement  
("Winking")




Some very small winking is normal or of no concern (due to the none infinite material stiffness)

Mobile vibration survey and monitoring may show if increasing

# Foundation Repair / Frame Foot Movement Check

## Frame foot oil contamination and relative movement




Mobile vibration measurement in 3 axes applied here to verify situation

Future checks recommended to monitor development

If oil penetrated between foot and shims (frame support) it is difficult to regain full strength to keep machine properly fixed on the foundation



## Foundation Repair / Frame Foot Movement Check



Application of dial gauge to identify foot movement in vertical direction when hydraulic pump pressure of the nuts on the anchor bolts is checked and – in case of lost tension – brought back to specified level.

In case of major dial gauge off-set the ground / frame foot support has become soft.

Oil contamination long term deteriorates concrete quality.

# Foundation Repair / Partial Foundation Repair

## Example No. 2

Partial foundation repair only at required points





## Foundation Repair / Partial Foundation Repair

Top of foundation had been chipped off according to requirements to achieve a clean surface for the new grouting





# Foundation Repair / New Anchor Bolt Installation (In Situ)

## Example No. 3




Machine frame anchor bolts had come loose and had no longer been able to hold the frame tight on the foundation

A large hole was drilled for each pair of new anchor bolts to be put in place – without removing the frame



Steel reinforcement being reconditioned

Foundation hole partly filled with epoxy grout



Repaired foundation with new anchor bolts - after the job was completed



## Foundation Repair / Complete Revamp

### Example No. 4




Oil emerging from lower section of the concrete foundation




Upper part of foundation mechanically removed as much as necessary to obtain:

- Oil free condition
- Solid concrete core

# Foundation Repair / Complete Revamp



Frame position  
check with  
plummet




Epoxy compound  
applied as grout



# Foundation Repair / Complete Foundation Repair (In Situ)

## Example No. 5




Relative movement

Cold joint

Vertical cracks

Poor concrete quality

## Foundation Repair / Complete Foundation Repair (In Situ)

A close-up view of formwork and new epoxy grout. The formwork is made of metal and wood, and the grout is a dark, viscous material being poured into the form. The text "Form work and new epoxy grout" is in a box above the image.

Form work and new epoxy grout



## **Foundation Repair / Complete Foundation Repair (In Situ)**



**Foundation Crack Repair by  
High Pressure Epoxy Injection**



**Refurbished Foundation with new  
Epoxy Grouting – Fit for Purpose**

# Foundation Repair / Anchor Bolt Crack

## Example No. 6

### Anchor Bolt Check



1. Partially cut off grouting and concrete
2. Open anchor sleeve
3. Pull anchor bolt





# Foundation Repair / Items which require Remedy

1. Oil contaminated grouting and concrete
2. Cracks in concrete foundation («Cold Joints»)
3. Soft layer below concrete block
4. Varying ground water level
5. Ice formation
6. «Sandy» foundation concrete (poor quality)
7. Poor grouting quality (soft and/or cracked)
8. Soft link between compressor frame and foundation ⇔ cracking bolts
9. High dynamic loads and moments
10. Anchor bolt corrosion
11. Poor or damaged (corroded or bent) anchor bolt support at the bottom of the anchor sleeve



# General Overhaul






# General Overhaul

## Frame Removal with Overhaul & Foundation Repair

### Not assessable Loads and Wear Phenomena:


- **Debris**
  - Liquids and Abrasive Solid Particles in the Gas
- **Corrosion**
  - Rain, High Air Humidity, Aggressive Atmosphere
- **Foundation Deterioration**
  - Weathering, High Dynamic Loads, Oil Leaks
- **Material- Fatigue**
- Bearings, Fasteners, Mating Contact Surfaces etc.
- **Vibrations**
  - Gas Dynamic and/or Mechanical Resonances



# General Overhaul

## Frame Removal with Overhaul & Foundation Repair

➡ The day will come when a General Overhaul is due



➡ Maintenance beyond the Scope of a Normal Revision or Repair



# General Overhaul

## Frame Removal with Overhaul & Foundation Repair

Piston compressor foundation and frame fixation typically suffer long term deterioration from:



- Unbalanced mass loads
- Oil penetration into the concrete
- Unfavourable ambient conditions (leading to ice formation and/or corrosion)
- Loose or cracked foundation bolts



# **General Overhaul**

## **Frame Removal with Overhaul & Foundation Repair**

**Example for Long Term  
“Wear & Tear”**



**Damaged and worn Flange Faces**



# General Overhaul

## Frame Removal with Overhaul & Foundation Repair

### Corrective Actions during the General Overhaul:

Example for Long Term  
“Wear & Tear”

1. The foundation

2. Mating surfaces of the

- Frame
- Distance pieces
- Cylinders

Damaged and worn Flange Faces

3. Complete Crankcase Check & Refurbishment

# General Overhaul

## Frame Removal with Overhaul & Foundation Repair

Various Parts were shipped to the Workshop for:

- Condition and dimension checks
- Repair and/or machining
- Replacement where necessary

### 1. Frame Reconditioning



Hyper Frame set up on Milling Machine



Milling head  
at work




Crank Cased being reworked



# General Overhaul

## Frame Removal with Overhaul & Foundation Repair

### Crank Case after Machining



# General Overhaul

## Frame Removal with Overhaul & Foundation Repair

### 2. Foundation Repair



Most of the old concrete had to be removed ...



... and reconditioned by application of Epoxy Resin




# General Overhaul

## Frame Removal with Overhaul & Foundation Repair



### 3. New Frame Support

Service Technicians guiding the Anchor Bolts into their Foundation Sleeves



# General Overhaul

## Frame Removal with Overhaul & Foundation Repair




Frame close to touch base ...

... to get settled on its new bed




# General Overhaul

## Frame Removal with Overhaul & Foundation Repair



# General Overhaul

## Frame Removal with Overhaul & Foundation Repair



1. Pipe connections are fixed and shall not be changed or adjusted
2. Motor position is given; only slight adjustment possible


### Consequence:

**Compressor orientation must be accurately determined before frame lifting or movement !**




# General Overhaul

## Frame Removal with Overhaul & Foundation Repair



# General Overhaul

## Frame Removal with Overhaul & Foundation Repair





# General Overhaul

## Frame Removal with Overhaul & Foundation Repair

### Laser-Technology



**Detector (SMR)**  
Mobile “Magic Eye”

... is held towards the object to be measured; it receives the laser beam from the tracker and reflects it back

**Transmitter  
(Laser Tracker)**  
Fixed

The tracker sends the laser beam to the reflective target – the “Magic Eye” prism mirror


**Notebook  
Computer**

... collects the coordinates of each point for data acquisition and evaluation through relevant software



# General Overhaul

## Frame Removal with Overhaul & Foundation Repair






# **General Overhaul**

## **Frame Removal with Overhaul & Foundation Repair**


### **Game Plan**

- 1. Determination of “as-build” condition**
- 2. Removal of crank case from foundation**
- 3. Transportation of crank case to the workshop**
- 4. Refurbishment of crank case and another parts**
- 5. Foundation repair**
- 6. Assembly of the crank case back on repaired foundation**
- 7. Adjustment of compressor frame to match E-motor axis and pipe flanges**



# Foundation Repair / Epoxy Grout Issues

In case of incorrect application:



Possible causes:

- Too high temperature
- Wrong mixing
- Poor bonding – presumably due to inadequate surface treatment






# Foundation Repair / Epoxy Grout Issues




Potential reasons for grout lift up:

- Missing top weight (gap)
- Poor heat transfer from bad/no (top) contact
- High local grout temperature with partially fast curing and uneven expansion/contraction
- High temperature differential between grout and base



## Foundation Repair / Epoxy Grout Issues

Here – as in many cases – epoxy compound was applied as grouting material; with wide pours; much larger than for typical chocks





## **Message “for the Road”**



**Your compressor deserves  
“Solid Footwear” ... !  
Make sure it is comfortable  
for the machine to run  
smoothly**

**I hope you enjoyed the presentation**

**Questions and Comments ?**

