

EFRC Training Workshop

Foundation Design for Reciprocating Compressors

Installation, Operation and Maintenance
Harry Lankenau – NEAC Compressor Service



EFRC Conference Training

9-Jul-14

Introduction



1

The “footwear” of the compressor is that what links it to the foundation:

1. Skid or
2. Anchorage and
3. Grouting



2



3

When the compressor is dispatched from the workshop it is practically “barefooted”.

At site the “shoes” are fitted to “run” well.

... and underneath is the foundation which shall be designed and built such to be a solid “walkway” !



EFRC Conference Training

9-Jul-14 2



Installation





EFRC Conference Training

9-Jul-14 3

Installation / Foundation Check – vs. Plan



- Check:**
- Dimensions
 - Position of Fixation Points
 - Orientation of Anchor Sleeves



Dynamic conditions such as max. permissible foundation movement (vibrations) and dynamic foundation loads shall be forwarded with the plan !



EFRC Conference Training

9-Jul-14 4

Installation / Foundation Check – Corrective Actions

Example for expensive “Corrective Actions”



foundation too short




anchor bolt position was off



EFRC Conference Training

9-Jul-14 5

Installation / Foundation Check – Surface Quality



Renewed Motor Foundation Block



In case of cracks check if only from curing at the top surface or deep through the block

Foundation top covered with mud which emerged during concrete curing generating a fine and sandy dust layer


The foundation top must be clean and rough to allow for perfect link with grouting to come; no (major) cracks shall be present.



EFRC Conference Training

9-Jul-14 6


Installation / Foundation Check – Jacking Screws/Spindles



EFRC Conference Training

9-Jul-14 7


Installation / Frame Flying-in and Positioning



EFRC Conference Training

9-Jul-14 8


Installation / Frame Level Check - Crankshaft



EFRC Conference Training

9-Jul-14 9

Installation / Frame Level Check – Crosshead Guide



EFRC Conference Training

9-Jul-14 10

Installation / Frame Level Check – Frame Top

Axial alignment on frame top surface



Level check in horizontal orientation - perpendicular to crank shaft axis




Note: Frame top is not a true face referring to crank shaft and main bearing bore (but often good enough to utilize ...)



EFRC Conference Training

9-Jul-14 11

Installation / Grouting Preparations



Wrapping of the anchor bolt with plastic foam, rubber or tape (*)

Anchor sleeve to be filled with :

- Glass Sand
- Polyurethane Foam




(*) In comparison with plastic foam or rubber the tape has the advantage of being much thinner, which enables easy fitting through the frame foot.



EFRC Conference Training

9-Jul-14 12

Installation / Grouting Procedure & Final "Shoe"



2nd layer of epoxy grouting may be required in case of elevated temperatures. Picture right: "Orange" quality on top of "Red" quality with better heat resistance



EFRC Conference Training

9-Jul-14 13

Operation



EFRC Conference Training

9-Jul-14 14

Operation / Foundation "Wear and Tear"

Foundation and grouting deteriorate from:

- Unbalanced mass loads
- Oil penetration into the grouting/concrete
- Unfavourable ambient conditions; such as ice formation; corrosion from aggressive atmosphere and ground water penetration
- Loose or cracked foundation bolts



EFRC Conference Training

9-Jul-14 15

Operation / Frame Foot Movement - Check

Gaps and movement had been visible here
Complete frame was rocking



Sometimes oil or water
bubbles indicate slight
relative movement
("Winking")



Some very small winking is normal or of no concern (due to the none infinite material stiffness)
Mobile vibration survey and monitoring may show if increasing




EFRC Conference Training

9-Jul-14 16

Operation / Frame Foot Movement - Vibration Monitoring

Frame foot oil contamination and relative movement



Mobile vibration measurement in 3 axes applied here to verify situation

Future checks recommended to monitor development


If oil penetrated between foot and shims (frame support) it is difficult to regain full strength to keep machine properly fixed on the foundation



EFRC Conference Training

9-Jul-14 17

Operation / Frame Foot Movement – Tightening Check



Application of dial gauge to identify foot movement in vertical direction when hydraulic pump pressure of the nuts on the anchor bolts is checked and – in case of lost tension – brought back to specified level.

In case of major dial gauge off-set the ground / frame foot support has become soft.


Oil contamination long term deteriorates concrete quality.



EFRC Conference Training

9-Jul-14 18

Operation / Grouting and Foundation – Defects



Such defects are not an indication for an issue.

Cracks as shown often occur.

Crack development (if any) must be observed and root cause found.

If foundation is soaked with oil and/or severe movement within unit detected; then action is required.



EFRC Conference Training

9-Jul-14 19

Maintenance
(Repair)



EFRC Conference Training

9-Jul-14 20

Maintenance / Partial Foundation Repair

Partial foundation repair only at required points



EFRC Conference Training

9-Jul-14 21

Maintenance / Foundation Repair – Complete Revamp



Oil emerging from lower section of the concrete foundation



Upper part of foundation mechanically removed as much as necessary to obtain:


- Oil free condition
- Solid concrete core




EFRC Conference Training

9-Jul-14 22

Maintenance / Foundation Repair – Complete Revamp



Frame position
check with
plummet




Epoxy compound
applied as grout



EFRC Conference Training

9-Jul-14 23

Maintenance / Complete Foundation Repair (In Situ)




Form work and new epoxy grout



EFRC Conference Training

9-Jul-14 24

Maintenance / Complete Foundation Repair (In Situ)




EFRC Conference Training

9-Jul-14 25

Maintenance / Foundation Bolt Repair (In Situ)

The section where the anchor bolt had been repaired was filled up with epoxy grout.




EFRC Conference Training

9-Jul-14 26

Maintenance / Epoxy Grout Issues

In case of incorrect application:



Possible causes:

- Too high temperature
- Wrong mixing
- Poor bonding – presumably due to inadequate surface treatment



EFRC Conference Training


9-Jul-14 27

Maintenance / Epoxy Grout Issues



Potential reasons for grout lift up:

- Missing top weight (gap)
- Poor heat transfer from bad/no (top) contact
- High local grout temperature with partially fast curing and uneven expansion/contraction
- High temperature differential between grout and base




EFRC Conference Training

9-Jul-14 28


Maintenance / Epoxy Grout Issues

Here – as in many cases – epoxy compound was applied as grouting material; with wide pours; much larger than for typical chocks



Maintenance / Foundation Issues which require Remedy

1. Oil contaminated grouting and concrete
2. Cracks in concrete foundation («Cold Joints»)
3. Soft layer below concrete block
4. Varying ground water level
5. Ice formation
6. «Sandy» foundation concrete (poor quality)
7. Poor grouting quality (soft and/or cracked)
8. Soft link between compressor frame and foundation ⇔ cracking bolts
9. High dynamic loads and moments
10. Anchor bolt corrosion
11. Poor or damaged (corroded or bent) anchor bolt support at the bottom of the anchor sleeve



EFRC Conference Training

9-Jul-14 30

**The foundation is the “path” on which the
compressor is “walking”**

**Make sure it is comfortable for the machine to
run smoothly**

Thank you for attending

I hope you enjoyed the presentation

Questions and Comments ?



EFRC Conference Training

9-Jul-14 31